




NOTES:

1. USE STEEL COVER IN SIDEWALK OR TRAIL AND HIGH DENSITY POLYETHYLENE (HDPE) COVER IN GREEN SPACES
2. MUST BE LABELED CITY OF ST LOUIS PARK ELECTRIC.
3. HANDHOLES ARE NOT ALLOWED IN THE ROADWAY, THE PEDESTRIAN ACCESS ROUTE (PAR) OR MAINTENANCE ACCESS ROUTE (MAR). MOVE EXISTING HANDHOLES TO MEET THESE REQUIREMENTS.
4. RING AND COVER FACE TO BE FREE OF CONCRETE.
5. 1/4" X 20 THREADED DRILLED AND TAPPED HOLES FOR GROUNDING.
6. BRAIDED STRAP –  
BURNDY WILEY – WILEYBRAID24 #6.  
SECURE STRAP TO COVER WITH 1/4" –  
20 X 5/8" HEX HEAD BOLT.
7. GROUND LUG –  
BURNDY – KA4C  
SECURE LUG TO RING WITH 1/4" –  
20 X 5/8" HEAD HEX BOLT.
8. CONSTRUCT 18" DEEP X 24" WIDE DRAINFIELD UNDER STRUCTURE USING 1.5" CRUSHED ROCK. (INCIDENTAL)